

# *Union Public Safety Department*

## *Special Event Requirements*

The following information is provided to you by the City of Union Public Safety Department Fire Division as a guide for vendors that are planning to take part in special public events located in the City of Union. This information outlines basic guidelines for the use of tents, canopies, food-vending booths, mobile concession stands and temporary structures. This guide is not inclusive of all regulations that govern public special events. **Revised: May 11, 2020 (IFC 2018)**

### **MOBILE FOOD PREPARATION VEHICLES**

**319.3 Exhaust hood.** Cooking equipment that produces grease-laden vapors shall be provided with a kitchen exhaust hood in accordance with Section 607.

**319.4.1 Fire protection for cooking equipment.** Cooking equipment shall be protected by automatic fire extinguishing systems in accordance with Section 904.12.

**319.4.2 Fire extinguisher.** Portable fire extinguishers shall be provided in accordance with Section 906.4.

**319.5 Appliance connection to fuel supply piping.** Gas cooking appliances shall be secured in place and connected to fuel-supply piping with an appliance connector complying with ANSI Z21.69/CSA 6.16.

**319.8.1 Maximum aggregate volume.** The maximum aggregate capacity of LP-gas containers transported on the vehicle and used to fuel cooking appliances only shall not exceed 200 pounds (91 kg) propane capacity.

**319.8.2 Protection of container.** LP-gas containers installed on the vehicle shall be securely mounted and restrained to prevent movement.

**319.8.4 Protection of system piping.** LP-gas system piping, including valves and fittings, shall be adequately protected to prevent tampering, impact damage, and damage from vibration.

**319.8.5 LP-gas alarms.** A *listed* LP-gas alarm shall be installed within the vehicle in the vicinity of LP-gas system components, in accordance with the manufacturer's instructions

# *Union Public Safety Department*

## *Special Event Requirements*

The following information is provided to you by the City of Union Public Safety Department Fire Division as a guide for vendors that are planning to take part in special public events located in the City of Union. This information outlines basic guidelines for the use of tents, canopies, food-vending booths, mobile concession stands and temporary structures. This guide is not inclusive of all regulations that govern public special events. **Revised: May 11, 2020 (IFC 2018)**

### **MOBILE FOOD PREPARATION VEHICLES**

**319.10.3 Fuel gas systems.** LP-gas containers installed on the vehicle and fuel-gas piping systems shall be inspected annually by an *approved* inspection agency or a company that is registered with the U.S. Department of Transportation to requalify LP-gas cylinders, to ensure that system components are free from damage, suitable for the intended service and

not subject to leaking. CNG containers shall be inspected every 3 years in a qualified service facility. CNG containers shall not be used past their expiration date as listed on the manufacturer's container label. Upon satisfactory inspection, the *approved* inspection agency shall affix a tag on the fuel gas system or within the vehicle indicating the name of the Inspection agency and the date of satisfactory inspection.

**904.12 Commercial cooking systems.** The automatic fire extinguishing system for commercial cooking systems shall be of a type recognized for protection of commercial cooking equipment and exhaust systems of the type and arrangement protected. Preengineered automatic dry- and wet-chemical extinguishing systems shall be tested in accordance with **UL 300** and *listed* and *labeled* for the intended application. Other types of automatic fire-extinguishing systems shall be *listed* and *labeled* for specific use as protection for commercial cooking operations. The system shall be installed in accordance with this code, NFPA 96, its listing and the manufacturer's installation instructions. Automatic fire-extinguishing systems of the following types shall be installed in accordance with the referenced standard indicated, as follows:

1. Carbon dioxide extinguishing systems, NFPA 12.
2. *Automatic sprinkler systems*, NFPA 13.
3. Automatic water mist systems, NFPA 750.

# *Union Public Safety Department*

## *Special Event Requirements*

The following information is provided to you by the City of Union Public Safety Department Fire Division as a guide for vendors that are planning to take part in special public events located in the City of Union. This information outlines basic guidelines for the use of tents, canopies, food-vending booths, mobile concession stands and temporary structures. This guide is not inclusive of all regulations that govern public special events. **Revised: May 11, 2020 (IFC 2018)**

### **MOBILE FOOD PREPARATION VEHICLES**

**906.4 Cooking equipment fires.** Fire extinguishers provided for the protection of cooking equipment shall be of an approved type compatible with the automatic fire-extinguishing system agent. Cooking equipment involving solid fuels or vegetable or animal oils and fats shall be protected by a Class K-rated portable extinguisher in accordance with Sections 906.1, Item 2, 906.4.1 and 906.4.2 as applicable.

**906.4.2 Class K portable fire extinguishers for deep fat fryers.** Where hazard areas include deep fat fryers, listed Class K portable fire extinguishers shall be provided as follows:

1. For up to four fryers having a maximum cooking medium capacity of 80 pounds (36.3 kg) each: one Class K portable fire extinguisher of a minimum 1.5-gallon ( 6 L) capacity.
2. For every additional group of four fryers having a maximum cooking medium capacity of 80 pounds (36.3 kg) each: one additional Class K portable fire extinguisher of a minimum 1.5-gallon (6 L) capacity shall be provided.
3. For individual fryers exceeding 6 square feet (0.55 m<sup>2</sup>) in surface area: Class K portable fire extinguishers shall be installed in accordance with the extinguisher manufacturer's recommendations.

**906.4.1 Portable fire extinguishers for solid fuel cooking appliances.** Solid fuel cooking appliances, whether or not under a hood, with fireboxes 5 cubic feet (0.14 m<sup>3</sup>) or less in volume shall have a minimum 2.5-gallon (9 L) or two 1.5-gallon (6 L) Class K wet-chemical portable fire extinguishers located in accordance with Section 906.1.

**[M] 607.1 General.** Commercial kitchen exhaust hoods shall comply with the requirements of the *International Mechanical Code*.

# *Union Public Safety Department*

## *Special Event Requirements*

The following information is provided to you by the City of Union Public Safety Department Fire Division as a guide for vendors that are planning to take part in special public events located in the City of Union. This information outlines basic guidelines for the use of tents, canopies, food-vending booths, mobile concession stands and temporary structures. This guide is not inclusive of all regulations that govern public special events. **Revised: May 11, 2020 (IFC 2018)**

### **MOBILE FOOD PREPARATION VEHICLES**

**[M] 607.2 Where required.** A Type I hood shall be installed at or above all commercial cooking appliances and domestic cooking appliances used for commercial purposes that produce grease vapors.

#### **Temporary structures, tents, canopies and air supported membranes:**

**3103.9 Structural stability and anchorage required.** Tents or membrane structures and their appurtenances shall be designed and installed to withstand the elements of weather and prevent collapsing. Documentation of structural stability shall be furnished to the *fire code official*.

**3103.2 Approval required.** Tents and membrane structures having an area in excess of 400 square feet (37 m<sup>2</sup>) shall not be erected, operated or maintained for any purpose without first obtaining a permit and approval from the *fire code official*.

#### **Exceptions:**

1. Tents used exclusively for recreational camping purposes.
2. Tents open on all sides that comply with all of the following:
  - 2.1. Individual tents having a maximum size of 700 square feet (65 m<sup>2</sup>).
  - 2.2. The aggregate area of multiple tents placed side by side without a fire break clearance of 12 feet (3658 mm), not exceeding 700 square feet (65 m<sup>2</sup>) total.
  - 2.3. A minimum clearance of 12 feet (3658 mm) to all structures and other tents.

**3106.5.1 Separation from tents or structures.** Cooking appliances or devices that produce sparks or grease-laden vapors or flying embers (firebrands) shall not be used within 20 feet (6096 mm) of a tent or temporary structure.

#### **Exceptions:**

1. Designated cooking tents not occupied by the public when *approved by the fire code official*.
2. *Tents* or structures where cooking appliances are

# *Union Public Safety Department*

## *Special Event Requirements*

The following information is provided to you by the City of Union Public Safety Department Fire Division as a guide for vendors that are planning to take part in special public events located in the City of Union. This information outlines basic guidelines for the use of tents, canopies, food-vending booths, mobile concession stands and temporary structures. This guide is not inclusive of all regulations that govern public special events. **Revised: May 11, 2020 (IFC 2018)**

### **MOBILE FOOD PREPARATION VEHICLES**

protected with an automatic fire-extinguishing system in accordance with Section 904.12.

**3107.12.6 Outdoor cooking.** Outdoor cooking that produces sparks or grease-laden vapors shall not be performed within 20 feet (6096 mm) of a tent or membrane structure.

**3107.3 Smoking.** Smoking shall not be permitted in *tents* or *membrane structures*. *Approved* “No Smoking” signs shall be conspicuously posted in accordance with Section 310.

**3107.4 Open or exposed flame.** Open flame or other devices emitting flame, fire or heat or any flammable or *combustible liquids*, gas, charcoal or other cooking device or any other unapproved devices shall not be permitted inside or located within 20 feet (6096 mm) of the *tent* or *membrane structures* while open to the public unless *approved* by the *fire code official*

**3107.3 Smoking.** Smoking shall not be permitted in *tents* or *membrane structures*. *Approved* “No Smoking” signs shall be conspicuously posted in accordance with Section 310.

**3106.5.2 Protection.** Cooking equipment using combustible oils or solids shall meet the following:

1. A noncombustible lid shall be immediately available. The lid shall be of sufficient size to cover the cooking well completely.
2. The equipment shall be placed on a noncombustible surface.
3. An *approved* portable fire extinguisher for protection from cooking grease fires shall be provided at a location *approved* by the *fire code official*.

# *Union Public Safety Department*

## *Special Event Requirements*

The following information is provided to you by the City of Union Public Safety Department Fire Division as a guide for vendors that are planning to take part in special public events located in the City of Union. This information outlines basic guidelines for the use of tents, canopies, food-vending booths, mobile concession stands and temporary structures. This guide is not inclusive of all regulations that govern public special events. **Revised: May 11, 2020 (IFC 2018)**

### **MOBILE FOOD PREPARATION VEHICLES**



**Class K 1½ Gallons**



**Class ABC 5lbs.**